


ADDENDUM NO. 4

**PROJECT NAME:
CONEJO CREEK SOUTHWEST PARK
DEVELOPMENT PROJECT**

August 9, 2021

This Addendum form is a part of the Contract Documents for the above-identified project and modifies the original Specifications and Contract Documents, as noted on the following pages. Portions of the Contract, not specifically mentioned in this Addendum, remain in force. All trades affected shall be fully advised of these changes, deletions, and additions.

The bid due date has changed to Monday, August 16, 2021 at 1:00 p.m.



Andrew Mooney
Senior Park Planner
Conejo Recreation and Park District

BIDDERS CERTIFICATE

I acknowledge receipt of all two (2) pages of this Addendum No. 4 and accept the aforementioned.

Bidders Signature

Date

**THIS DOCUMENT TO BE SIGNED
AND SUBMITTED WITH BID**

ADDENDUM NO. 4

**PROJECT NAME:
CONEJO CREEK SOUTHWEST PARK
DEVELOPMENT PROJECT**

August 9, 2021

The following additions and/or corrections shall become a part of the Contract Documents and Specifications for the above named project. When submitting a bid for the project, this Addendum shall be acknowledged and ***a signed copy of the Addendum shall be included in the bid package.***

Changes or clarifications are noted are BOLD and UNDERLINED

I. GENERAL

The bidder is directed to make the following corrections, deletions, and/or additions to the contract documents and contract drawings heretofore dispensed to him for the above project, and to note bidder's receipt of this addendum by number on the attached ***Addenda Acknowledgement Form:***

II. MODIFICATIONS TO PREVIOUS ADDENDA

N/A

III. BIDDING AND CONTRACT REQUIREMENT REVISIONS

A. Bid Opening date changed to Aug 16th 1:00pm.

IV. PLAN REVISIONS

N/A

V. RFI

Question 1: The soils report states the soils could be "rocky and could contain significant amounts of large gravel to cobble sized fragments". The same report says to remove any fragments over 6" in diameter. However, specification section 312323 "Fill" states to remove lumps larger than 3" and rocks larger than 2". Please clarify.

Answer 1: Utilize the soils report for instructions.

When submitting a bid for the project, this Addendum shall be acknowledged and a signed copy of the Addendum shall be included in the bid package